



TRAVANCORE TITANIUM PRODUCTS LIMITED  
Kochuveli, Thiruvananthapuram 695 021

Phone : 0471 2502163 FAX: 0471 2501533

CD/CN/VC-275/11KV UG Cables /18-19

30-10-2018

**Tender Notice**

**” Laying of 11KV UG cables in between 66/11KV Transformer No.A to Incomer of Transformer no A at 66KV Receiving station.”**

Sealed quotations are invited from experienced Contractors in prescribed format for doing the work of ” **Laying of 11KV UG cables in between 66/11KV Transformer No.A to Incomer of Transformer no A at 66KV Receiving station.**The tender shall be enclosed in an envelope, sealed and superscribed with Tender number, date and due date and description as ” **Laying of 11KV UG cables in between 66/11KV Transformer No.A to Incomer of Transformer no A at 66KV Receiving station**”The same shall then be forwarded to **“The Head of the Department(C), Travancore Titanium Products Limited, Kochuveli P O, Thiruvananthapuram, Kerala Pin 695 021.**

The tender form can be obtained from the office of the under signed between 9.00am and 4.00 pm on all working days, after remitting the tender form cost. **Cost of tender form. Rs.500/- +GST 18% (Rs.590/-)** Tender document can also be downloaded from our website ([www.travancoretitanium.com](http://www.travancoretitanium.com)). They shall submit the Tender along with a DD against the tender form cost & EMD in favour of Travancore Titanium Products Limited payable at Thiruvananthapuram.

**EMD: Rs.1350/- (refundable) (By cash/DD)**

Sealed Tenders will be received at our office on all working days and the last date of submitting the same is on **13-11-2018** at 12 noon. Tenders received after the due date & time will not be accepted. Fax/email offers also will not be accepted.

The bids will be opened on 2 pm on **13-11-2018** in the presence of the tenderers present at that time.

for TRAVANCORE TITANIUM PRODUCTS LIMITED

Encl: Proforma

  
**Head of the Department(Comm)**

Signature of the bidder:

Page 1 of 7



TRAVANCORE TITANIUM PRODUCTS LIMITED  
Kochuveli, Thiruvananthapuram 695 021

Phone : 0471 2502163 FAX: 0471 2501533

CD/CN/VC-275/11KV UG Cables /18-19

30-10-2018

### Tender Notice

**" Laying of 11KV UG cables in between 66/11KV Transformer No.A to Incomer of Transformer no A at 66KV Receiving station."**

Tenders are invited for Laying 11 KV, 3C x 400Sq.MM HT XLPE UG Cable from 66/11KV Transformer No.A to 11KV Incomer of Transformer No.A HT Panel at receiving station of M/s TTPL.

#### **I. Scope of Work**

- 1) This specification covers, removing the existing 11KV PILC UG cable from 66/11KV Transformer No.A to Incomer of Transformer no.A HT Panel at receiving station and shift the removed cable to cable yard.
- 2) Excavate Cable Trench for laying new 11KV HT cable from 66/11KV Transformer No.A to Incomer H.T Panel of Transformer no A.
- 3) 140meter length of New 11 KV, 3C x 400Sq.MM HT XLPE UG Cable shall be supplied by M/s TTPL to contractor at free of cost
- 4) Laying 140meter length of New 11 KV, 3C x 400Sq.MM HT XLPE UG Cable from 66/11KV Transformer No.A to 11KV HT Incomer panel of Transformer No.A at receiving station
- 5) Size of Cable trench shall be as per Electrical Inspectorate standard.
- 6) Required fixing supports for HT cables shall be provide by contractor
- 7) Contractor shall collect 140meter length XLPE cable from general store of M/s TTPL and bring to 66KV yard as per direction of officer in charge
- 8) New cable shall be lay through trenches and provide required quantity of GI/FRP Pipes for road crossing. G.I/FRP Pipes shall be supplied by contractor.
- 9) Cable trays if required shall be supplied by the contractor
- 10) Soiling, provide bricks, warning tape, back fill the trench are under the scope of contractor
- 11) Cable root marker shall be provided at every 50meter distance.

Signature of the bidder:

Page 2 of 7

